


DS71-MD4 Reset Procedure



1. Press and hold reset button as you power cycle the module.
2. Continue to hold button for 45 seconds, then release button.
3. Use Terminal program into the serial port if not already doing so.
4. If no opening menu, Type 5 semi-colons.
5. If appears not to work repeat reset procedure except hold button for 60 seconds.

Any questions or concerns arising from this procedure should be directed to the BayTech support team at:

support@baytech.net
Bay Technical Associates
5236 A Avenue
Long Beach, MS 39560
Domestic: 800.523.2702
International: 228.563.7335