

RPC 22, 27, 28

To reset the unit to factory default:

1. Turn the power of to the RPC unit
2. Remove the panel to the left of the BayTech logo on the front of the unit
3. Directly behind the BayTech logo at the top you'll see a 2 pin jumper
4. Place a jumper on those 2 pins and power up for 15 seconds
5. Turn power off, and remove the jumper

The unit will now be rest to factory default

Any questions or concerns arising from this procedure should be directed to the BayTech support team at:

support@baytech.net

Bay Technical Associates

200 North Second St.

Bay St. Louis, MS 39520

Domestic: 800.523.2702

International: 228.467.8231